



# Nonlinear Control of Thermoelectric Peltier Moduls for Climate Management Systems in Agro-Industrial Complex

G. Vasilyev<sup>1,1(✉)</sup>, O. Kuzichkin<sup>1</sup>, and D. Surzhik<sup>2</sup>

<sup>1</sup> Belgorod National Research University, 85, st. Pobedy, Belgorod 308015, Russia  
vasilievgleb@yandex.ru

<sup>2</sup> Vladimir State University, 23, st. Orlovskaya, Vladimir 602264, Russia

**Abstract.** Due to the global shortage of energy resources and a sharp increase in their cost, the problems of energy conservation become more and more urgent. A promising approach to solving the problem of energy saving is based on the principle of trigeneration, which implies the simultaneous production of electrical and thermal energy and makes it possible to reduce the energy intensity of production and the cost of agricultural products. Based on this method, the structural diagram of thermoelectric climate control system and its equivalent functional model have been developed. Transient processes of the linear and nonlinear thermoelectric climate control system for agricultural facilities with various coefficients of two saturation blocks have been obtained using the MatLAB Simulink environment. From their analysis it was found that the use of nonlinear control has significant advantages over the linear control and can reduce the time of transients, dynamic control error and oscillation.

**Keywords:** Thermoelectric system · Peltier module · Nonlinear control · Climate control

## 1 Introduction

Every year, due to the global shortage of energy resources and a sharp increase in their cost, the problems of energy conservation become more and more urgent [1–6]. They are especially acute in the sectors of the agro-industrial complex (AIC) [7], where for a number of objects it is mandatory to create a special microclimate for production, which requires significant energy costs [8].

The solution to this problem in many countries of the world at the moment is reduced to the installation of special energy-saving equipment at agricultural facilities and/or technical re-equipment of the energy supply systems used. In addition, a number of authors note the prospects of using an integrated approach to solving the problem of energy saving based on the principle of trigeneration [9–11], which implies the simultaneous production of electrical and thermal energy, which makes it possible to reduce the energy intensity of production and the cost of agricultural products.

As one of the main components for building multifunctional trigenerative systems, it is proposed to use the thermoelectric method [12–17], which is characterized by a number of key advantages (environmental friendliness, exceptional reliability of components, the possibility of extremely fast cooling, high accuracy of temperature control, independence of module parameters from gravity and orientation in space, low sensitivity to high mechanical loads, no need for maintenance). This method is based on the use of the Peltier effect [18–21] (absorption or release of heat during the flow of direct electric current through dissimilar conductors), implemented using thermoelectric modules (TEM).

### 1.1 Thermoelectric Climate Control System for Agro-Industrial Facilities

The use of the thermoelectric method of obtaining heat and cold makes it possible to implement on its basis a climate control system for agro-industrial facilities [12, 13]. The microclimate control with its help is carried out under the action of control variables in the form of control currents  $I_C$ , which are functionals of the desired temperature values of the  $T_D$  and the results of temperature measurements using sensors  $T_S$

$$I_C = f(T_D, T_S) \quad (1)$$

The use of a hybrid ventilation system for agricultural facilities based on the convection principle of cooling makes it possible to carry out heat and cold removal from the junctions of thermoelectric modules to create a non-stationary temperature field in the premises of the form  $T = f(x, y, z, t)$ , where  $x, y, z$  - spatial coordinates,  $t$  - time.

This field is three-dimensional and non-stationary and is formed using point sources of heat or cold, each of which is described by the Fourier differential equation for heat conduction in the presence of internal heat sources of the form Orlov [22]

$$\frac{\partial T}{\partial t} = a \partial^2 T + \frac{q_V}{c\rho} \quad (2)$$

Where  $a = \frac{\lambda}{c\rho}$  the coefficient of thermal diffusivity,  $\lambda$  - coefficient of thermal conductivity,  $c$  - specific heat capacity,  $\rho$  - density,  $\partial^2 T = \frac{\partial^2 T}{\partial x^2} + \frac{\partial^2 T}{\partial y^2} + \frac{\partial^2 T}{\partial z^2}$  - the Laplace operator,  $q_V$  - the amount of heat released per unit volume of the medium per unit time.


A special case of this equation is convective heat transfer [22], in which the processes of convection and heat conduction proceed jointly

$$\frac{\partial T}{\partial t} + w_x \frac{\partial T}{\partial x} + w_y \frac{\partial T}{\partial y} + w_z \frac{\partial T}{\partial z} = a \nabla^2 T \quad (3)$$

where  $w_x, w_y, w_z$  are the projections of the velocity vector on the X, Y, Z axes.


On the basis of the considered principle, a structural diagram of a thermoelectric climate control system for agro-industrial complex facilities has been developed, shown in Fig. 1. This circuit is the simplest and includes a single Peltier thermoelectric module (TEM), its temperature controller (TC), a ventilation system (VS) with a single point source of heat/cold, a single temperature sensor (TS) and an inertia compensator (IC) for this sensor. The following designations are adopted on the scheme:  $T_d$  - desired temperature;  $I_C$  - control current for Peltier thermoelectric module;  $T_{PS}$  is the temperature

of the point source of heat/cold;  $T_S$  - temperature at the outlet of the temperature sensor;  $T_{Scomp}$  - temperature at the outlet of the temperature sensor after passing through the inertia compensator.



**Fig. 1.** Structural diagram of thermoelectric climate control system for AIC.

On the basis of this scheme, its equivalent functional model has been developed - Fig. 2, where the following designations are adopted:  $T_{int}(p)$  - interference effect simulating the processes of heat exchange between the environment and the external sides of the TEM;  $H_{TC}(P)$  - transfer function of the temperature controller;  $H_{AZ}(p)$  - transfer function of the aperiodic link of the temperature controller (used to reduce the inertia of the Peltier thermoelectric module);  $H_{TEM}(p)$  - transfer function of the Peltier thermoelectric module;  $H_{VC}(p)$  - ventilation system transfer function;  $H_S(p)$  - temperature sensor transfer function;  $H_{IC}(p)$  - transfer function of the inertia compensator;  $p$  is the Laplace operator;  $k_I$  and  $k_P$  are the transfer coefficients of the integral and proportional components of the temperature controller.



**Fig.2.** Equivalent functional model of a thermoelectric climate control system for AIC.

The transfer functions of the main structural links, as well as the entire system as a whole for useful and interference effects are presented in detail in Grinkevich [23–25].

### 1.2 Linear and Non-Linear Control by Peltier Thermoelectric Module in Climate Control Systems for AIC

The developed climate control system for agribusiness facilities must correspond to a certain quality of the control process, which is determined by the behavior of the system during the transition to a new mode of operation [26–28].

In this article, for comparative analysis, two types of climate control systems are used: linear and non-linear, the functional models of which in the MatLAB Simulink environment with weight coefficients and transfer functions are shown in Fig. 3.

The nonlinearities in Fig. 3b are introduced by two Saturation blocks (signal clipping) in order to compensate for undesirable effects from the natural TEM nonlinearities, as well as to give the control system improved quality indicators. The static characteristic of this piecewise linear single-valued (each value of the input quantity  $x$  corresponds to one specific value of the output quantity  $z$ ) continuous nonlinearity is shown in Fig. 4 and the analytical one is given as

$$Z = \begin{cases} B & \text{at } X > b; \\ kX & \text{at } |X| \leq b; \\ -B & \text{at } X < -b. \end{cases} \quad (4)$$

In the case when the linear part of the system is equivalent to a low-pass filter, for these links it is possible to use the method of harmonic linearization, the idea of which is based on the use of an equation obtained by discarding higher harmonics in the expansion of a nonlinear function in a Fourier series. In operator form, this expression has the form

$$z = q(A)x + q'(A)\frac{px}{\omega} \quad (5)$$

where  $q(A) = \frac{B_1}{A}$ ,  $q'(A) = \frac{A_1}{A}$  are the harmonic linearization coefficients, determined for the selected type of nonlinearity as


$$q(A) = \frac{2B}{\pi b} \left[ \arcsin \frac{b}{A} + \frac{b}{A^2} \sqrt{A^2 - b^2} \right]; q'(A) = 0 \text{ at } A \geq b. \quad (6)$$

Using the developed models, a study was made of the operation of the proposed climate control system in the time domain for linear (blue color) and non-linear (brown color) TEM control modes for various saturation block values - Figs. 5 and 6. Amplitude and phase responses of the linear model from frequency are shown in Fig. 7, its transient response at the stepwise input of amplitude 1 - in Fig. 8. The results of modeling the output parameter of the nonlinear TES at different amplitudes of the input parameter with coefficients of the first saturation block (2; -2) and the second (0.8; -0.8) are shown in Fig. 9.


## 2 Conclusion

From the graphs obtained, it can be concluded that the use of a nonlinear TEM control algorithm makes it possible to impart properties to the climate control system that are fundamentally unattainable by traditional linear means. This is manifested in providing extremely high speed during transients (decreased by 2–20 times), as well as reducing the dynamic control error and oscillation in the presence of the same structural elements, their coefficients and natural restrictions on the levels of control and interference effects.


Thus, the proposed approach to nonlinear control in climate control systems for agro-industrial complex can serve as an effective variant of TEM control, which allows solving the problems of optimization and synthesis of this class of devices with improved characteristics and quality indicators.”




**Fig. 3.** Linear (a) and nonlinear (b) functional models of a thermoelectric climate control system for AIC in the MatLAB Simulink environment.




**Fig. 4.** Static characteristic of the nonlinearity of saturation (limitation) of signals.




**Fig. 5.** a transient process of the thermoelectric climate control system for AIC with coefficients of the first saturation block (2; -2) and the second (0.7; -0.7); b transient process of the thermoelectric climate control system for agricultural facilities with coefficients of the first saturation block (2; -2) and the second (0.8; -0.8).




**Fig.6.** Transient process of the thermoelectric climate control system for agricultural facilities with coefficients of the first saturation block (2; -2) and the second (0.9; -0.9).



**Fig. 7.** Amplitude (a) and phase (b) responses of the linear system.



**Fig. 8.** Transient response of the linear system at the stepwise input of amplitude 1.



**Fig. 9.** The results of modeling the output parameter of the nonlinear TES at different amplitudes of the input parameter: **a** 1; **b** 3; **c** 5; **d** 7.

**Acknowledgments.** The work was prepared within the framework of the state task of the Russian Federation “Research and development of complex energy-saving and thermoelectric regenerative systems” application number 2019-1497, subject number FZWG-2020-0034.

## References

1. Danilov, N.I., Shchelokov, Y.M.: Basics of Energy Saving, 569 p. HOU VPO UGTU-UPI, Ekaterinburg (2006)
2. Berezovsky, N.I., Berezovsky, S.N., Kostyukevich, E.K.: Energy Saving Technology: Textbook, 356 p. BIP-C Plus, Minsk (2007)
3. Andrizhievskii, A.A., Volodin, V.I.: Energy Saving and Energy Management: Textbook, 294 p. Higher School (2005)
4. Samoilov, M.V., Punicic, V.V.: Basics of Energy Saving: Textbook, 200 p. BGEU (2002)
5. Ganja, V.L.: Fundamentals of Efficient Use of Energy Resources: Theory and Practice of Energy Saving, 451 p. Belarusian Science, Minsk (2007)
6. Eremkin, A.I., Koroleva, T.I., Danilin, G.V.: Economic Efficiency of Energy Saving in Heating, Ventilation and Air Conditioning Systems, 321 p. Publishing House of the Association of Construction Universities (2008)
7. Minakov, I.A., Kulikov, O.V., Sokolov, N.I.: Industry Economics APK, p. 464. Coloss, Moscow (2004)
8. Vishnevsky, E.P., Salin, M.Y.: Microclimate at the objects of agro-industrial complex. Plumb. Heat. Air Cond. Plumb. Heat. Air Cond. **8**(116), 86–89 (2011)
9. Galimova, L.V., Slavin, R.B.: Analysis of efficiency of a trigeneration energy-saving system. Refrig. Eng. **3**, 16–19 (2012)
10. Wang Ji, W., Zheng, C.Y.: Analysis of trigeneration system in combined cooling and heating mode. Energy Build. **72**, 353–360 (2014)

11. Surzhik, D.I., Kuzichkin, O.R., Vasilyev, G.S.: An integrated approach to the construction of energy-saving trigeneration systems for objects of the agro-industrial complex. *Int. J. Eng. Res. Technol.* **13**(12), 4622–4626 (2021)
12. Surzhik, D.I., Vasilyev, G.S., Kuzichkin, O.R., Konstantinov, I.S.: Construction of energy-saving cooling and thermoelectric regenerative systems based on Peltier modules. *Int. Multidiscip. Sci. GeoConference Surv. Geol. Min. Ecol. Manag. (SGEM)* **4**(1), 37–44 (2020)
13. Kuzichkin, O.R., Konstantinov, I.S., Vasilyev, G.S., Surzhik, D.I.: Principles of construction of microclimate control and management systems in agro-industrial production based on identification algorithms. *Adv. Dyn. Syst. Appl.* **16**(1), 299–311 (2021)
14. Anatychuk, L.I.: *Thermoelements and Thermoelectric Devices*, 768 p. Kiev (1979)
15. Bernstein, A.S.: *Thermoelectric Generators*, p. 48. Gosenergoizdat, Moscow (1956)
16. Evdulov, O.V.: *Development of Devices and Systems for Cooling Based on High-Current Thermoelectric Energy Converters*, 330 p. Dissertation for the Degree of Doctor of Technical Sciences, Makhachkala (2019)
17. Zone, A.P.: Determining the conditions for obtaining the maximum energy efficiency of the Peltier element. *News Southwest. State Univ.* **3**(20), 153–158 (2016)
18. Gnusin, P.I.: Study of the Peltier element efficiency in various operating modes. *Video Sci.* **1**(1), 20–27 (2016)
19. Ohrem, V.G.: Thermoelectric cooling using the Peltier effect. *Appl. Phys.* **5**, 123–126 (2016)
20. Gorobets, N.V., Ohrem, V.G.: Peltier thermoelectric cooler with additional conductive element. *Appl. Phys.* **4**, 124–127 (2007)
21. Ohrem, V.G.: New Peltier thermoelectric coolers for deep cooling. *Appl. Phys.* **4**, 121–127 (2006)
22. Orlov, M.E.: *Theoretical Foundations of Heat Engineering*, 204 p. Heat and Mass Transfer, UIGTU, Ulyanovsk (2013)
23. Grinkevich, V.A.: Synthesis of a temperature controller for the Peltier element. *Collect. Sci. Work. NSTU* **1**(94), 7–31 (2019)
24. Grinkevich, V.A.: Synthesis of current regulator for Peltier element. *Collect. Sci. Work. NSTU* **3–4**(93), 16–39 (2018)
25. Grinkevich, V.A.: Research of a mathematical model of a thermostat based on the Peltier element. *Collect. Sci. Pap. NSTU* **3**(89), 62–77 (2017)
26. Vasilyev, G.S., Kuzichkin, O.R., Surzhik, D.I.: Method for modeling dynamic modes of nonlinear control systems for thermoelectric modules. *Adv. Dyn. Syst. Appl.* **15**(2), 187–197 (2021)
27. Kuzichkin, O.R., Konstantinov, I.S., Vasilyev, G.S., Surzhik, D.I.: Control of operability of Peltier modules in cooling systems based on the analysis of transient operating modes. *Arch. Thermodyn.* **42**(2), 31–42 (2021)
28. Kuzichkin, O.R., Surzhik, D.I., Vasilyev, G.S., Shcherbinina, N.V.: Algorithm for monitoring the operability of Peltier thermoelectric modules based on the identification of transients. *J. Phys. Conf. Ser.* **2016**(1), 012007 (2021)